

# Lane Regional Air Protection Agency Standard Air Contaminant Discharge Permit

# **REVIEW REPORT**

**Junction City Clean Fuels** 92757 Highway 99S Junction City, Oregon 97448 **Permit No. 203147** 

## **Source Information:**

Primary SIC	4922
Secondary SIC	4911
Primary NAICS	486210
Secondary NAICS	221117
Public Notice	III
Category	

Source Category (LRAPA title 37,	B.48: Natural gas and oil production and	
Table 1)	processing and associated fuel burning equipment	

**Compliance and Emissions Monitoring Requirements:** 

Unassigned emissions	N
Emission credits	N
Compliance schedule	N
Source test [date(s)]	EU-1: 8760 hrs
	operation or 3 years

•		
	COMS	N
	CEMS	N
	CPMS	N
	Ambient monitoring	N

**Reporting Requirements** 

Annual report (due date)	2/15
Emission fee report (due date)	N
Semi-Annual Report (due date)	N
Greenhouse Gas Report (due date)	3/31

Quarterly report (due dates)	N
Monthly report (due dates)	N
Excess emissions report	Υ
Other reports	N

**Air Programs** 

NSPS (list subparts)	A, JJJJ
NESHAP (list subparts)	N
Compliance Assurance Monitoring (CAM)	N
Regional Haze (RH)	N
Synthetic Minor (SM)	N
SM-80	N
Part 68 Risk Management	N
Major FHAP source	N

Federal major source	N
TACT	N
Type A State New Source Review	N
Type B State New Source Review	N
Prevention of Significant Deterioration (PSD)	N
Nonattainment New Source Review (NNSR)	Υ
Cleaner Air Oregon	N

Junction City Clean Fuels LLC

Expiration Date: November 19, 2030

Permit No. 203147

Page 2 of 16

## **Permittee Identification**

- 1. The Junction City Clean Fuels facility ('JCCF' or 'the facility'), owns and operates a renewable natural gas and biogas electric power generation facility located at 92757 Highway 99, Junction City, Oregon.
- 2. The facility operates under the primary Standard Industrial Classification (SIC) code of 4922 Natural Gas Transmission and the primary North American Industry Classification System (NAICS) code of 486210 Pipeline Transportation of Natural Gas.
- 3. The facility operates under the secondary Standard Industrial Classification (SIC) code of 4911 Electric Services and the secondary North American Industry Classification System (NAICS) code of 221117 Biomass Electric Power Generation.

## **General Background**

4. JCCF's primary operation consists of generating biogas derived from an anaerobic digester, then cleaning the biogas to produce pipeline quality gas which is injected into the natural gas pipeline. The secondary operation consists of biogas to produce electricity for the electrical power grid. The facility consists of a 1,550 ekW bio-fired generator, two (2) 7.0 MMBtu/hr natural gas-fired boilers, Type 1 and Type 2 feedstock handling systems with baghouse and carbon filter, solid/liquid mixing pump unit hoppers with carbon filter, a CO<sub>2</sub> stripper vessel – biogas upgrade vent, and paved roads. The facility also has the following categorically insignificant activities: an anaerobic digester, dewatering tank, diesel storage tank, four (4) condensate tanks, and two (2) 200 kW natural gas-fired emergency generators.

### **Reason for Permit Action and Fee Basis**

5. The proposed permit is a renewal of an existing Standard Air Contaminant Discharge Permit (ACDP) that was issued on August 28, 2019 and was originally scheduled to expire on August 28, 2024. The renewed Standard ACDP will be valid for up to five (5) years.

## **Attainment Status**

6. The facility is located in an attainment area for all criteria pollutants. The facility is located within 100 kilometers of three (3) Class I air quality protection areas: Diamond Peak Wilderness, Mount Washington Wilderness and Three Sisters Wilderness area.

# **Permitting History**

7. LRAPA has reviewed and issued the following permitting actions to this facility since the last Standard ACDP renewal was issued on August 28, 2019:

Date(s) Approved/Valid Permit Action Type		Description	
08/28/2019 - 08/28/2024	Standard ACDP	Renewal	
07/12/2021	Basic Tech. Mod.	Addendum No.1 to update the kilowatt rating of the stand-by generators, include previously omitted NSPS Subpart JJJJ language for EU-1, remove one waste biogas flare from EU-2, remove NSPS Subpart Dc references for EU-3, and remove EU-6, EU-9, EU-10, and the categorically insignificant diesel-fired fire pump engine.	

Date(s) Approved/Valid Permit Action Type		Description	
01/08/2024	Simple Tech. Mod.	Addendum No. 2 to change the generators from "standby" to "emergency" and other associated changes.	
09/22/25	Non-Tech. Mod.	Addendum No. 3 to change the name of the permittee.	
Upon Issuance	Standard ACDP	Renewal	

## **Emission Unit Descriptions**

8. The emission units (EU) regulated by the permit are the following:

Emission Unit ID	Description	Pollution Control Device (PCD ID)	Installed / Last Modified
EU-1	Biogas-fired Generator, Combined Heat and Power manufactured by 2G/MWM in 2012, Rated at 1,550 ekW, (at 1800 rpm, 60Hz)	None	2013
EU-2	Enclosed waste flare	None	2018
EU-3	Two (2) boilers, natural gas-fired, 7.0 MMBtu/hr	None	2021
EU-4	Type 1 Feedstock Handling System	Baghouse, BH1	2021
EU-5	Type 2 Feedstock Handling System	Carbon Filter, Odor Control	2021
EU-7	Solid/Liquid Mixing Pump Unit Hoppers	Carbon Filter, Odor Control	2021
EU-8	CO <sub>2</sub> Stripper Vessel, biogas upgrade vent	None	2021
EU-Fugitive Emissions (FE)	Paved Road Dust	None	NA
EU- Categorically Insignificant Activities (CIA)	<ul> <li>Dewatering Tank Vent</li> <li>Anaerobic digesters using green feedstock</li> <li>Diesel Storage Tank</li> <li>Four (4) Condensate Tanks</li> <li>Two (2) Emergency Generators, natural gas-fired, 200 KW each</li> </ul>	None	2021

# Significant Emissions Units

# 9. Emission Unit EU-1

The facility has one (1) 2G/MWM biogas-fired internal combustion engine generator to produce electrical power that is not currently in use.

# 10. Emission Unit EU-2

The facility uses an enclosed flare to combust excess gas.

## 11. Emission Unit EU-3

The facility operates two (2) boilers each with a heat input rating of 7.0 MMBtu per hour. These boilers operate on natural gas.

Junction City Clean Fuels LLC

Expiration Date: November 19, 2030

Permit No. 203147

Page 4 of 16

## 12. Emission Unit EU-4 and EU-5

The facility operates a Type 1 Feedstock Handling System and a Type 2 Feedstock Handling System, in EU-4 and EU-5, respectively. EU-4 is controlled by a baghouse (BH1) and EU-5 is controlled by a carbon filter for odor control.

#### 13. Emission Unit EU-7

The facility operates Solid/Liquid Mixing Pump Unit Hoppers in EU-7. EU-7 is controlled by a carbon filter for odor control.

#### 14. Emission Unit EU-8

The facility operates a biogas upgrade vent in EU-8 named as a CO<sub>2</sub> Stripper Vessel. EU-8 is uncontrolled.

#### 15. Emission Unit EU-FE

Emissions Unit EU-Fugitive Emissions (FE) is for particulate emissions from vehicle traffic on paved roads within the facility.

#### 16. Emission Unit EU-CIA

Emissions Unit EU-Categorically Insignificant Activities (CIA) includes devices and activities that are defined as CIA in LRAPA's Title 12 - Definitions.

#### **Nuisance, Deposition and Other Emission Limitations**

- 17. Under LRAPA 49-010(1), the permittee must not cause or allow air contaminants from any source subject to regulation by LRAPA to cause a nuisance. Compliance is demonstrated through documentation of all complaints received by the facility from the general public and following procedures to notify LRAPA of receipt of these complaints.
- 18. Under LRAPA 32-055, the permittee must not cause or permit the emission of particulate matter which is larger than 250 microns in size at sufficient duration or quantity as to create an observable deposition upon the real property of another person. Compliance is demonstrated through documentation of all complaints received by the facility from the general public and following procedures to notify LRAPA of receipt of these complaints.
- 19. Under LRAPA 32-090(1), the permittee must not discharge from any source whatsoever such quantities of air contaminants which cause injury or damage to any persons, the public, business or property; such determination is to be made by LRAPA. Compliance is demonstrated through documentation of all complaints received by the facility from the general public and following procedures to notify LRAPA of receipt of these complaints.

### **General Emission Limits and Standards**

- 20. The facility is subject to the visible emissions limitations under LRAPA 32-010(3). For sources, other than wood-fired boilers, no person may emit or allow to be emitted any visible emissions that equal or exceed an average of 20 percent opacity for a period or periods aggregating more than three (3) minutes in any one (1) hour. Compliance will be demonstrated through a monthly visible emissions survey, annual inspection requirements for baghouses, and implementation of an Operation & Maintenance Plan for pollution control devices.
- 21. The facility is subject to the visible emission limitation under LRAPA 32-015(1)&(2)(b)(B). For fuel burning equipment installed, constructed or modified on or after June 1, 1970 but prior to April 16,

Junction City Clean Fuels LLC Expiration Date: November 19, 2030 Review Report Permit No. 203147 Page 5 of 16

2015 for which there are not represented compliance test results prior to April 16, 2015, the particulate matter emission limit is 0.14 grains per dry standard cubic foot. Compliance will be demonstrated through a monthly visible emissions survey, annual inspection requirements for baghouses, and implementation of an Operation & Maintenance Plan for pollution control devices.

- 22. The facility is subject to the visible emission limitation under LRAPA 32-030(2). For fuel burning equipment installed, constructed or modified on or after April 16, 2015 for which there are not represented compliance test results prior to April 16, 2015, the particulate matter emission limit is 0.10 grains per dry standard cubic foot. Compliance will be demonstrated through a monthly visible emissions survey, annual inspection requirements for baghouses, and implementation of an Operation & Maintenance Plan for pollution control devices.
- 23. Under LRAPA 32-007(1), the facility is required to prepare an Operation and Maintenance Plan (O&M Plan) for the particulate matter control devices that exhaust to the atmosphere. If the O&M Plan is updated, the facility must submit the updated copy to LRAPA for review. If LRAPA determines the plan is deficient, LRAPA may require the facility to amend the plan. In addition, at least annually, the permittee is required to inspect each baghouse exhausting to the atmosphere and maintain a log of the inspection and any actions taken.
- 24. Under LRAPA 32-007(1), the facility is required to prepare an Operation and Maintenance Plan (O&M Plan) for the carbon filter that controls VOC and federal HAP emissions. If the O&M Plan is updated, the facility must submit the updated copy to LRAPA for review. If LRAPA determines the plan is deficient, LRAPA may require the facility to amend the plan.

#### Typically Achievable Control Technology (TACT)

- 25. LRAPA 32-008(1) requires an existing unit a facility prior to January 1, 1994 to meet TACT if the emission unit meets the following criteria: The emission unit is not already subject to emission standards for the regulated pollutant under LRAPA title 30, title 32, title 33, title 38, title 39 or title 46 at the time TACT is required; the source is required to have a permit; the emission unit has emissions of criteria pollutants equal to or greater than five (5) tons per year of particulate or ten (10) tons per year of any gaseous pollutant; and LRAPA determines that air pollution control devices and emission reduction processes in use for the emissions do not represent TACT and that further emission control is necessary to address documented nuisance conditions, address an increase in emissions, ensure that the source is in compliance with other applicable requirements, or to protect public health or welfare or the environment.
  - 25.a. None of the emission units at the facility were in existence prior to January 1, 1994 and are therefore not required to meet TACT for existing sources.
- 26. LRAPA 32-008(2) requires new units installed or existing emission units modified on or after January 1, 1994, meet TACT if the emission unit meets the following criteria: The emission unit is not subject to Major NSR or Type A State NSR in LRAPA title 38, and applicable NSPS in LRAPA title 46, or any other standard applicable to only new or modified sources in LRAPA title 32, title 33, or title 39 for the regulated pollutant; the source is required to have a permit; if new, the emission unit has emissions of any criteria pollutant equal to or greater than one (1) ton per year of any criteria pollutant; if modified, the emission unit would have an increase in emissions of any criteria pollutant equal to or greater than one (1) ton per year of any criteria pollutant; and LRAPA determines that the proposed air pollution control devices and emission reduction processes do not represent TACT.
  - 26.a. The following emission units are not subject to TACT because they are subject to an applicable Standard of Performance for New Stationary Sources in title 46: EU-1.
  - 26.b. The following emission units are not subject to TACT because they do not have emissions of criteria pollutants equal to or greater than one (1) ton per year: EU-5 and EU-7.

Junction City Clean Fuels LLC

Expiration Date: November 19, 2030

Permit No. 203147

Page 6 of 16

26.c. The following emission units are subject to TACT because they have emissions of criteria pollutants equal to or greater than one (1) ton per year: EU-2, EU-3, EU-4, and EU-5. While a formal TACT analysis has not been conducted, TACT for these emission units would likely be the development and use of an O&M plan and documentation of inspections and maintenance on these emission units. Controls are not considered economically feasible for such small boilers.

#### **New Source Performance Standards (NSPS)**

- 27. Emission Unit EU-1 is subject to 40 CFR part 60 subpart JJJJ Standards of Performance for Stationary Spark Ignition Internal Combustion Engines because it is a digester gas-fire stationary engine greater than 500 HP located at an area source of HAP that was constructed on or after 6/12/2006.
- 28. The emergency generators in Emissions Unit EU-CIA are subject to 40 CFR part 60 subpart JJJJ Standards of Performance for Stationary Spark Ignition Internal Combustion Engines because they are emergency stationary engines less than or equal to 500 HP located at an area source of HAP that was constructed on or after 6/12/2006.

#### National Emission Standards for Hazardous Air Pollutants (NESHAP)

29. There are no NESHAPs that apply to any of the existing Emissions Units at the facility.

### Plant Site Emission Limits (PSELs)

30. Provided below is a summary of the baseline emissions rate, netting basis, plant site emission limit, and potential-to-emit:

	Baseline	J		Plant Site Emission Limit (PSEL)		DTE
Pollutant	Emission Rate (TPY)	Previous (TPY)	Proposed (TPY)	Previous PSEL (TPY)	Proposed PSEL (TPY)	PTE (TPY)
PM	0	0	0	24	15	15
PM <sub>10</sub>	0	0	0	14	5.2	5.2
PM <sub>2.5</sub>	NA	0	0	9	2.9	2.9
CO	0	0	0	99	83	83
NO <sub>x</sub>	0	0	0	39	37	37
SO <sub>2</sub>	0	0	0	39	28	28
VOC	0	0	0	39	3.4	3.4
GHG (CO <sub>2</sub> eq)	0	0	0	74,000	70,280	70,280

- 31. The facility has no baseline emission rates for PM, PM<sub>10</sub>, SO<sub>2</sub>, NO<sub>x</sub>, CO, and VOC because the facility was not in operation during the 1978 baseline year. A baseline emission rate is not established for PM<sub>2.5</sub> in accordance with LRAPA 42-0048(3). The facility has no baseline for GHGs because the facility had no GHG emissions during any consecutive 12 calendar month period during calendar years 2000 through 2010.
- 32. The netting basis for all pollutants is set at zero because the facility was constructed after the 1978 baseline year and the facility has not had any emission increases approved for any of the reasons listed under LRAPA 42-0046(3)(e).

Junction City Clean Fuels LLC Expiration Date: November 19, 2030

Review Report Permit No. 203147 Page 7 of 16

33. The PSELs s were reset to the potential emission rate from the significant emissions units as required by subsection 42-0041(3). The previous PSELs were based on Generic PSELs that are no longer allowed by rule.

### Significant Emission Rate (SER) Analysis

34. The PSEL increase over the netting basis is less than the Significant Emission Rate (SER) as defined in LRAPA title 12 for all pollutants as shown in the following table.

Pollutant	Proposed PSEL (TPY)	PSEL Increase Over Netting Basis (TPY)	PSEL Increase Due to Utilizing Existing Baseline Period Capacity (TPY)	PSEL Increase Due to Modification (TPY)	SER (TPY)
PM	15	15	NA	NA	25
PM <sub>10</sub>	5.2	5.2	NA	NA	15
PM <sub>2.5</sub>	2.9	2.9	NA	NA	10
CO	83	83	NA	NA	100
NO <sub>x</sub>	37	37	NA	NA	40
SO <sub>2</sub>	28	28	NA	NA	40
VOC	3.4	3.4	0	0	40
GHGs	70,280	70,280	NA	NA	75,000

### New Source Review (NSR) and Prevention of Significant Deterioration (PSD)

35. This source is located in an area that is designated attainment or unclassified for all regulated pollutants. The proposed PSELs are less than the federal major source threshold for non-listed sources of 250 TPY per regulated pollutant and are not subject to Major NSR.

#### Federal Hazardous Air Pollutants/Toxic Air Contaminants

- 36. Potential annual federal hazardous air pollutant emissions (FHAP) are based on the potential to emit of the facility operating under permit limitations:
  - 36.a. Formaldehyde has the highest single FHAP emissions at approximately 3.0 tons per year.
  - 36.b. The potential total FHAP emissions are 3.2 tons per year.
  - 36.c. The detail sheets in this review report contain a table of FHAP emissions as well as toxic air contaminants (TAC) emissions.
- 37. A major source of FHAPs is defined as having potential FHAP emissions of at least 10 tons per year of any single HAP and 25 tons per year of the aggregate of all FHAPs. This facility does not have potential FHAP emissions exceeding these thresholds and is considered a minor or area source of FHAPs.
- 38. Under the Cleaner Air Oregon program, only existing sources that have been notified by LRAPA and new sources are required to perform risk assessments. This source has not been notified by LRAPA and, therefore, is not yet required to perform a risk assessment or report annual emissions of toxic air contaminants. LRAPA required reporting of approximately 600 toxic air contaminants in 2016 and regulates approximately 260 toxic air contaminants (TAC) that have Risk Based Concentrations established in rule. All FHAPs are on the list of approximately 600 TACs. The FHAPs and TACs listed

Junction City Clean Fuels LLC

Expiration Date: November 19, 2030

Permit No. 203147

Page 8 of 16

below are based upon safety data sheets and standard emission factors for the types of emission units at this facility. After the source is notified by LRAPA, they must update their inventory and perform a risk assessment to see if they must reduce risk from their TACs. Until then, this source will be required to report TAC emissions triennially.

### **Performance Testing**

- 39. In accordance with NSPS Subpart JJJJ, performance testing must be conducted to demonstrate compliance with the NOx, CO, and VOC emission standards for the biogas generator in EU-1. The facility was required to conduct an initial performance test within one (1) year of engine startup, which was completed on November 18, 2014. Subsequent performance testing is required every 8,760 hours of operation or three (3) years, whichever is earlier.
- 40. The facility conducted source testing on EU-1 in 2014, 2016, 2017 and 2018, and those results are summarized in the emission detail sheets as part of this review report. Currently EU-1 is not operated.
- 41. If the gas-fired emergency generators in the Categorically Insignificant Activity emission unit are noncertified or are not operated and maintained according to the manufacturer's written emission-related instructions, then an initial performance test is required per NSPS Subpart JJJJ.

## **Compliance History**

42. There have been no enforcement actions issued to the facility and no inspections that determined the facility was in non-compliance.

### Monitoring and Recordkeeping Requirements

43. The facility is required to keep and maintain all records of the following information for a period of at least five (5) years and have available within 24 hours of a request from LRAPA:

Emission Source	Recordkeeping	Minimum Recording Frequency				
	Biogas burned in the engine generator (MMBtu)	Monthly				
	Hours of Operation for the engine generator (hrs)	Monthly				
Biogas Generator (EU-1)	Maintenance performed in accordance with the Subpart JJJJ NSPS	Upon occurrence				
	Results of biogas fuel analysis for heat content and/or composition	Upon occurrence				
	Source test records in accordance with Condition 14.c	Upon occurrence				
Waste Biogas Flare, Enclosed (EU-2)	Biogas burned by the excess biogas flare (MMBtu)	Monthly				
Boilers (EU-3)	Natural gas burned in the boilers (cubic feet)	Monthly				
Emergency Generators	Maintenance conducted	As performed				
(Categorically Insignificant Activity)	Maintenance Plan	Maintain current (non-certified engines only)				
Activity)	Hours of operation (hours)	Upon occurrence				

Junction City Clean Fuels LLC Expiration Date: November 19, 2030

Emission Source	Recordkeeping	Minimum Recording Frequency		
Baghouse (EU-4)	Pressure drop readings (inches of water)	Monthly		
(20-4)	Inspections	Monthly		
Carbon Filter Odor Control (EU-5 and EU-7)	Updated and Reviewed O&M Plan	Annually		
Upgrade Vent (EU-8)	Hours of operation	Monthly		
Type 1 Feedstock, Type 2 Feedstock and Digestate Removal (Fugitive Emissions)	Number of loads received/outgoing	Annually		
All Factories Haits	Odor complaints received by the permittee	Upon occurrence		
All Emission Units	EPA Method 9 or Method 22 visible emission observations	As performed		

## **Reporting Requirements**

44. The facility must submit to LRAPA the following reports no later than the dates indicated in the table below:

Report	Reporting Period	Due Date
PSEL pollutant emissions, including supporting calculations. The summary must include emission calculations corresponding to each 12-month consecutive period in the previous calendar year.	Annual	February 15
A summary of maintenance and repairs performed on any pollution control devices at the facility.	Annual	February 15
Updated O&M Plan (if updated)	Annual	February 15
GHG Report	Annual	March 31
A summary of all complaints received by the permittee and their resolution	Annual	February 15
The excess emissions log, if any planned or unplanned excess emissions have occurred during the reporting period.	Annual	February 15

# **Public Notice**

45. Pursuant to LRAPA 37-0066(4)(a)(A), issuance of renewed Standard Air Contaminant Discharge Permit requires public notice in accordance with LRAPA 31-0033(3)(c), which requires LRAPA to provide notice off the proposed permit action and a minimum of 35 days for interested persons to submit written comments.

The draft permit was on public notice from Monday October 13, 2025, to Tuesday November 18, 2025. No written comments were submitted during the 35-day comment period.

# **Emission Detail Sheets**

**Emissions Summary** 


Emissian Unit	Description	PM	PM10	PM2.5	CO	NOx	SOx	VOC	GHG (CO2e)
Emission Unit	Description	tons/year							
EU-FE	Paved Road - Vehicular	11.51	2.30	0.56					
EU-1	Biogas Generator CHP	0.44	0.44	0.44	30.76	30.66	13.30	0.93	11732
EU-2	Flare - Enclosed	1.02	1.02	1.02	45.05	2.40	14.56	0.51	12839
	Boiler #1	0.11	0.11	0.11	3.59	2.13	0.03	0.23	5143
EU-3	Boiler #2	0.11	0.11	0.11	3.59	2.13	0.03	0.23	5143
EU-4	Type 1 Feedstock Handling System (Straw System Fugitives & Baghouse)	1.84	1.14	0.60			1	1	-
EU-5	Type 2 Feedstock Handling System (Odor Control - Manure Handling)	0.09	0.04	0.006	-		1	1	-
EU-7	Solid/Liquid Mixing Pump Unit Hoppers (Odor Control - Biomix)				-			0.187	3993
EU-8	CO2 Stripper Vessel, Gas Upgrade Vent				-		-	1.27	31429
	Total	15	5.2	2.9	83	37	28	3.4	70280
	SER	25	15	10	100	40	40	40	75000


EU-1 CHP Emissions									
	197335701.6	cf/yr			66427080	dscf/yr	66.42708		
Generator Heat Input	111100	MMBtu/yr		Biogas flow rate	7583	dscf/hr			
Generator Emission Factors	Proposed	Units	Reference				Pollutant	Proposed	
PM	0.008	lb/MMbtu	Existing permit				Pollutant	TPY	
PM10	0.008	lb/MMbtu	Existing permit				PM	0.44	
PM2.5	0.008	lb/MMbtu	Existing permit				PM10	0.44	
co	0.554	lb/MMbtu	Source test data (ave)				PM2.5	0.44	
NOx	0.552	lb/MMbtu	Source test data (ave)				СО	30.76	
SOx	0.2395	lb/MMbtu	Existing permit				NOx	30.66	
voc	0.017	lb/MMbtu	Source test data (ave)				SOx	13.30	
CH4	3.20E-03	kg/MMbtu	EPA 40 CFR Part 98				VOC	0.93	
N2O	6.30E-04	kg/MMbtu	EPA 40 CFR Part 98				CH4	0.39	
CO2 Combustion	52.07	kg/MMbtu	EPA 40 CFR Part 98				N2O	0.08	
CO2 Biogenic	43.47	kg/MMbtu	EPA 40 CFR Part 98				CO2 Combustion	6377	
							CO2 Biogenic	5324	
Global Warming Potential							CO2e	11732	
CO2	1								
CH4	28								
N2O	265								
Source Test Results	Cas Flaur (m2/hr)	Cas flow (of /hr)	Heat Input (MMBtu/hr)	CO (llh /hr)	CO (Ib /Manbau)	NOv (lb/bs)	NOx (lb/MMBtu)	VOC (Ib /b=)	\/OC (   \/ \/ \/ \/ \/ \/ \/ \/ \/ \/ \/ \/ \/
Source Test Results 2014									VOC (lb/MMBtu) 0.045
2014		22312							0.045
2016									0.011
2017		20158 17489	9.85						0.006
Average	495.2	17469	9.63	6.20					

EU-2 Enclosed Flare					Enclosed Flare Emis	sions					
20 2 Endiosed Flare						Enclosed Flare					
Higher Heating Values (HHV)					Pollutant	TPY					
Combined Biogas		btu/cf		185.61564	PM	1.02					
Other biomass gases		btu/cf		203/01301	PM10	1.02					
Methane		btu/cf			PM2.5	1.02					
					СО	45.05					
Flare Operating Hours	876	hours			NOx	2.40					
Flare Gas Flowrate	6000	m3/hr	211890	ft3/hr	SOx	14.56					
Flare heat input	139	MMbtu/hr			VOC	0.51					
	121578.2	121578.2442		185615640	CH4	0.43					
Pilot Light Operating Hours	8760	hours			N2O	0.08					
Pilot light heat input	0.05	MMbtu/hr	total	185615640	CO2 Combustion	6978					
					CO2 Biogenic	5826					
Open Flares					CO2e	12839					
Higher Heating Values (HHV)											
Combined Biogas		btu/cf									
Cellulosic Biogas		btu/cf									
Methane	1010	btu/cf									
Flare Operating Hours		hours		5.0.0							
Flare Gas Flowrate		m3/hr	35315	ft3/hr							
Flare heat input	23.13	MMbtu/hr									
Enclosed Flare Emission Factor	nre				Enclosed Flare Emis	sion Factors	Ref.				
PM		lb/10 <sup>6</sup> dscf Methane	2 22	lb/hr Biogas	PM		EPA AP42	2.4-5			
PM10		lb/10 dscf Methane		Ib/hr Biogas	PM10		EPA AP42				
PM2.5		lb/10 dscf Methane					EPA AP42				
				lb/hr Biogas	PM2.5						-
СО		lb/10 <sup>6</sup> dscf Methane		lb/hr Biogas	со		EPA AP42				
NOx		lb/10 <sup>6</sup> dscf Methane	5.49	lb/hr Biogas	NOx		EPA AP42				
SOx		lb/MMbtu			SOx					-	entration in ga
VOC		lb/10 <sup>6</sup> dscf NG		Ib/MMbtu Biogas	VOC			2 1.4-2 conve	rted to bio	gas by HHV	
CH4		kg/MMbtu		lb/MMbtu	CH4			R Part 98			
N2O		kg/MMbtu		lb/MMbtu	N2O		EPA 40 CI				
CO2 Combustion		kg/MMbtu		lb/MMbtu	CO2 Combustion		EPA 40 CF				
CO2 Biogenic	43.47	kg/MMbtu	95.84	Ib/MMbtu	CO2 Biogenic	43.47	EPA 40 CF	R Part 98			
Pilot Light Emission Factors											
PM	7.6	lb/10 <sup>6</sup> dscf NG	0.007525	lb/MMbtu							
PM10		lb/10 <sup>6</sup> dscf NG		Ib/MMbtu							
PM2.5		lb/10 <sup>6</sup> dscf NG		lb/MMbtu							
CO CO		lb/10 dscf NG		lb/MMbtu							
NOx		lb/10 <sup>6</sup> dscf NG		lb/MMbtu							
SOx		lb/10 <sup>6</sup> dscf NG		lb/MMbtu							
VOC		lb/10 <sup>6</sup> dscf NG		lb/MMbtu							
CH4		kg/MMbtu		lb/MMbtu							
N2O		kg/MMbtu		Ib/MMbtu							
CO2 Combustion	53.06	kg/MMbtu	116.98	Ib/MMbtu							
Global Warming Potential											
CO2	1										
CH4	28										
N2O	265										

EU-3 Boiler #1 & #2 Emis	sions					<b>Boiler Emissions</b>			
						Dellutont	Boiler #1	Boiler #2	Total
Hours of operation	8760	hours	170760234	cf/year		Pollutant	TPY	TPY	TPY
Input Capacity	10	MMBtu/hr				PM	0.11	0.11	0.21
NG HHV	1026	btu/cf				PM10	0.11	0.11	0.21
	85.38011696					PM2.5	0.11	0.11	0.21
Boiler Emission Factors	Value	Units	Value	Units	Ref.	CO	3.59	3.59	7.17
PM	2.5	lb/10 <sup>6</sup> dscf	0.0024	lb/MMbtu	DEQ AQ-EF05	NOx	2.13	2.13	4.27
PM10	2.5	lb/10 <sup>6</sup> dscf	0.0024	lb/MMbtu	DEQ AQ-EF05	SOx	0.03	0.03	0.05
PM2.5	2.5	lb/10 <sup>6</sup> dscf	0.0024	lb/MMbtu	DEQ AQ-EF05	VOC	0.23	0.23	0.47
со	84	lb/10 <sup>6</sup> dscf	0.0819	lb/MMbtu	DEQ AQ-EF05	CH4	0.10	0.10	0.19
NOx	50	lb/10 <sup>6</sup> dscf	0.0487	lb/MMbtu	DEQ AQ-EF05	N2O	0.06	0.06	0.12
SOx	0.6	lb/10 <sup>6</sup> dscf	0.0006	lb/MMbtu	Facility Data	CO2 Combustion	5124	5124	10247
VOC	5.5	lb/10 <sup>6</sup> dscf	0.0054	lb/MMbtu	DEQ AQ-EF05	CO2e	5143	5143	10287
CH4	1.00E-03	kg/MMbtu	0.002	lb/MMbtu	EPA 40 CFR Part 98				
N2O	6.00E-04	kg/MMbtu	0.001	lb/MMbtu	EPA 40 CFR Part 98				
CO2 Combustion	53.06	kg/MMbtu	116.98	lb/MMbtu	EPA 40 CFR Part 98				
Global Warming Potentia	al								
CO2	1								
CH4	25								
N2O	298								

F 1	l Hivo Footer	ione		A D 42 C = c+1	an 12 2 4	1			
	tive Emiss			AP42 Section	on 13.2.4	-4			
Throughput		ton/year		The	quantity of p	articulate emiss	ons generated by eit	her type of drop ope	ration, per kilogran
Exposed sites	14			(kg) (ton) of expression:	material trai	nsferred, may be	ons generated by eith estimated, with a rat	ing of A, using the	following empirical
Wind speed (U)		m/s		enpression:		, ,			
		mph				$\left(\frac{\mathrm{U}}{22}\right)^{1.3}$			
Straw moisture (M)	4	%		E =	= k(0.0016)	$\frac{\left(\frac{1}{2.2}\right)}{\left(\frac{M}{2}\right)^{1.4}}$ (kg	/megagram [Mg])		
PM30	k=	0.74				(2)			
PM10	k=	0.35				( 11) 13			
PM2.5	k=	0.053				$\left(\frac{0}{5}\right)^{12}$ (no			
				Е:	= k(0.0032)	${\left(M\right)^{1.4}}$ (pc	und [lb]/ton)		
PM30	EF=	0.002228	lb/ton			$\left(\frac{1}{2}\right)^{1/2}$			
PM10	EF=	0.001054	-			` /			
PM2.5	EF=	0.00016		where:					
		0.00010	,	E =	emission fa	ctor			
Fugitive Emissions	(@ th≙ 1/1 :	i exnosed si	tes)	k =	particle size mean wind	e multiplier (dim speed, meters pe	ensionless) er second (m/s) (mile	s per hour [mph])	
PM30	1.326	tons/year		M =	material mo	oisture content (	%)	1 t t t t t t t	
PM10	0.627	tons/year		The particle	size multipli	er in the equation	n, k, varies with aeroo	dynamic particle size	e range, as follows:
PM2.5	0.027	tons/year		+		Verodynamic Por	ticle Size Multiplier (	k) For Equation 1	
PIVIZ.3	0.095	toris/year		< 30 µ		< 15 μm	< 10 μm	< 5 μm	< 2.5 μm
<b>n</b>	l			0.74	I	0.48	0.35	0.20	0.053ª
Бад	house Sys	tem		<sup>a</sup> Multiplie	r for < 2.5 μι	n taken from Re	erence 14.		•
		0.040	11. /						
PM	EF=		lb/ton straw proc						
PM10	EF=		lb/ton straw proc						
PM2.5	EF=	0.012	lb/ton straw proc	essed					
Point Emissions									
PM		tons/year							
PM10	0.510	tons/year	-						
PM2.5	0.510	tons/year							
EF	Baghouse	and Fugit	ives Combined						
PM	EF=	0.014							
PM10	EF=	0.013							
PM2.5	EF=	0.012							
-									
Emissions	1.04	tons/year							
Emissions PM	X4								
PM		tonelypa	•						
PM PM10	1.14	tons/year							
PM PM10	1.14	tons/year							
PM	1.14 0.60	tons/year	-						





Junction City Clean Fuels LLC Expiration Date: November 19, 2030

EU-8 Gas Upgra	de - Amine S	crubber Vent	Emissions			
	0/ Emittod	CC lb/br	llo /ve	TDV	TDV CO2o	
	% Emitted	EF lb/hr	lb/yr	TPY	TPY CO2e	
Vented CO2	100%	mb		30491	30491	
CH4 loss	0.1%	mb		33.51	938	
H2S	98%	mb		0.16		
VOC	95%	0.31	2548	1.27		
						lb/hr
						18689.96
VOC Emission F	actor					
	Raw Gas	Raw Gas	VOC	VOC		81862.03
VOC	Flow Rate	Flow Rate	EF	EF		
mg/m3	mscfh	m3/hr	mg/hr	lb/hr		
30	163.5	4630	138,894	0.31		
Process Engine	ering MB					
biogas	production	m3/a	40,569,153			
methane	production	m3/a	21,242,157			
		%methane	52.36%			
specific weight	0oC	kg/m3	1.32			
specific weight	50oC	kg/m3	1.4342			

PM30	gitive Emission k=		lb/VMT			Travel Di-	tancos (ha	cod on cit	e drawings):					
PM10	k=		Ib/VMT				ft -trucks	seu on siti	e urawings).					
														mitigati
PM2.5	k=	0.00054	lb/VMT				ft -bale ha							inversel
						/50	ft - emplo	yee						applicat a daily
sL=		g/m <sup>2</sup>												a daily
P			(at least 0	.01" rainfa	all)									
N	365	days per	year											
Assumnt	ions Made by th	e Facility												
155411161	lons made by an	c r demicy												where k
vehicle I	Miles/Trips Trav	elled:			Total VMT/year				Vehicle Weights	::				where k
	VMT for straw		product tr	in	Employees		VMT/year		W=		tons, stra	w truck w	eight	
	VMT for bale h		•		Straw Trucks		VMT/year		W=		tons, manure truck weight			
	VMT for emplo				Manure Trucks		VMT/year		W=				hicle weight	
	employee trip				Bale Handlers		VMT/year		W=		tons, bale handler weight			
	straw truck trip				Product Trucks		VMT/year		W=		tons, product truck weight			
	bale handler to		13071		Maintenance		VMT/year		W=		tons, maintenance		Weight.	
	manure truck t		15071			500	· · · · · / / cu			7.5	10115, 11141			
	product truck t													
		1 - 7 7												
PM30 EF				PM10 EF				PM2.5 EF						
	Employees	0.0929	lb/VMT		Employees	0.0186	lb/VMT		Employees	0.0046	lb/VMT			
	Straw Trucks		lb/VMT		Straw Trucks		lb/VMT		Straw Trucks		lb/VMT			
	Manure Trucks	1.6388	lb/VMT		Manure Trucks	0.3278	lb/VMT		Manure Trucks	0.0804	lb/VMT			
	Bale Handlers	0.6436	lb/VMT		Bale Handlers	0.1287	lb/VMT		Bale Handlers	0.0316	lb/VMT			
	Product Trucks	1.6388	lb/VMT		Product Trucks	0.3278	lb/VMT		Product Trucks	0.0804	lb/VMT			
	Maintenance		lb/VMT		Maintenance		lb/VMT		Maintenance		lb/VMT			
PM30 Em	issions			PM10 Em	issions			PM2.5 En	nissions					
	Employees	0.0408	ton/year		Employees	0.0082	ton/year		Employees	0.0020	ton/year			
	Straw Trucks	1.7624	ton/year		Straw Trucks		ton/year		Straw Trucks		ton/year			
	Manure Trucks		ton/year		Manure Trucks		ton/year		Manure Trucks		ton/year			
	Bale Handlers	0.6345	ton/year		Bale Handlers	0.1269	ton/year		Bale Handlers	0.0311	ton/year			
	Product Trucks		ton/year		Product Trucks		ton/year		Product Trucks		ton/year			
	Maintenance		ton/year		Maintenance		ton/year		Maintenance		ton/year			
								Ì					VMT/Load	
	Total PM30	11.5	ton/year		Total PM10	2.3	ton/year		Total PM2.5	0.6	ton/year			rce Estimate